



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/08/2025

Incharge(s): Lal Singh

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|------------------------|--|----------------------|----------------------|-------------|
| 1 | OHP | BRC ON CO-32 | BC NOT RUNNING | DUE TO JAMMING INFORMED OPR | 08:30:00 | 08:45:00 | |
| 2 | CHP | CC-36 SCR-1 | NO DRIVES WORKING | MAIN MCCB TRIPPED ... MADE ON AND TESTED | 10:50:00 | 11:20:00 | |
| 3 | CHP | CC-39 SCR-7 | LT NOT WORKING | PCRD OT... RELEASED | 11:20:00 | 11:30:00 | |
| 4 | CHP | CC-44 | TRIPPED ON OLR | RESET DONE | 10:10:00 11:00:00 | 10:20:00 11:10:00 | |
| 5 | CHP | CC-27A | STOPPED ON CHUT SENSOR | WIRE LOOSE IN CJB ... BYPASSED | 10:15:00 | 10:40:00 | KEPT IN CKT |
| 6 | CHP | CC-28 | TRIPPED ON OLR | RESET | 11:00:00 12:20:00 | 11:10:00 12:25:00 | |
| 7 | CHP | CC-114 | TRIPPED ON OLR | RESET DONE | 11:45:00 | 11:54:00 | |
| 8 | CHP | CC-26 | STOPPING ON ZSS | CAGE STUCK ... MADE FREE | 06:50:00 | 07:00:00 | |
| 9 | CHP | CC-40 SCR-3 | LT NOT WORKING | DRIVE TRIPPED ... RESET DONE | 13:40:00 | 13:50:00 | |
| 10 | WT | CC-3 BD | TRIPPED ON OLR | RESET DONE | 07:10:00 | 07:15:00 | |