



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/08/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co-34	LT NOT working	ot acted ... released ... informed mech for guide adjustment	04:15:00	04:30:00	
2	OHP	co-29	olr acted	reset	00:13:00	00:40:00	
3	OHP	brc ON CO-31	LT NOT WORKING	M6 MOTOR TRIPPED ... RESET	05:30:00	05:45:00	
4	OHP	CO-67	TRIPPED ON OVERLOAD	RESET DONE	23:20:00	23:25:00	
5	OHP	CO-63 CD	OLR ACTED DUE TO TRACK JAM	RESET (3 TIMES)	02:30:00	04:35:00	
6	CHP	cc-104 scr-9	LT NOT WORKING	PCRD OT ... RELEASED	03:00:00	03:15:00	
7	CHP	CC-111 S-3	SIGNAL PROBLEM	PLC POWER RECYLED	03:10:00	03:25:00	
8	CHP	CC-32 SCR-5	BC NOT RUNNING	OLR ACTED ... RESET	03:54:00	04:05:00	
9	CHP	CC-39	OLR ACTED	RESET DONE	04:30:00	04:35:00	
10	CHP	CC-51	TRIPPED ON OLR	RESET	02:35:00 23:55:00	02:40:00 00:00:00	
11	CHP	CC-51	MPD TRIP	RESET	23:30:00	23:35:00	
12	CHP	CC-51	TIS MOTOR TRIPPED	RESET	01:20:00	01:25:00	
13	CHP	CC-54	TRIPPED ON OLR	RESET	03:45:00	03:50:00	
14	CHP	CC-132	TRIPPED ON OLR	RESET DONE	04:55:00	05:05:00	
15	WT	SCO-1A	BD TRIPPED	RESET DONE	01:45:00 03:45:00	01:50:00 03:50:00	