



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/08/2025

Area: CHP

Equipment	Job
CC 131 LDB	CABLE DRESSING DONE,REPLACED DAMAGED CONNECTORS AND IMPROVED LIGHTING
SCr 10	Lower MCC floor empty places covered with checkered plates
CC 112,S 3,CC 44	PPM was done
SCR 10	Boom conveyor new motor shifted and placed on the bed and bolted
CC 37	Chute sensor,ZSS,PC,BSS kept in ckt . Temporarily laid power cables removed and shifted