



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/11/2025

Area: IOSA

Equipment	Job
OC-15A	PPM DONE ON MOTOR .
OC-7A	CJB DOOR HAS COME OUT. DOOR FIXED BACK AFTER FIXING HINGES.
OC-36A	DEFECTIVE LIGHT FITTINGS REMOVED AND LIGHT FITTING PROVIDED IN CONVEYOR GALLERY.
OTT-1A	MATERIAL CLEARED FROM COMPOSITE CABLE AT OC-11A GALLERY. CABLE ROUTED THROUGH CABLE TRAY.
OC-9A	ZSS CAGE AND MODULE FIXED. TAKEN INTO LINE AND FEEDBACK CHECKED.
THRUSTER BRAKES	REMOVED FROM SCR-9 AND SHIFTED LC-2 SHED FOR TESTING.