



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/05/2025

Area: WT

Equipment	Job
LC 1	All drive panels and I/O panel blowing room cleaning done
OP 5	Bottom C -clamp found damaged ,replaced it and trolley line checked up to col no 60 from 80 ,OK
OP 2,3,4,5,6 and 7	after rake maintenance done