



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/09/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment      | Problem                                                      | Action                                                         | From                             | To                               | Remarks |
|-------|------|----------------|--------------------------------------------------------------|----------------------------------------------------------------|----------------------------------|----------------------------------|---------|
| 1     | OHP  | CO-29          | OLR ACTED (3TIMES)                                           | RESET DONE                                                     | 08:00:00<br>09:00:00<br>10:00:00 | 08:10:00<br>09:10:00<br>10:10:00 |         |
| 2     | OHP  | WOBR ON CO-26  | REPORTED SLEW NOT WORKING CHECKED OLR ACTED                  | RESET DONE (2TIMES)                                            | 08:15:00<br>11:45:00             | 08:30:00<br>12:00:00             |         |
| 3     | OHP  | TT-3 ON BIPC-1 | REPORTED POSITION INDICATION MISSING DUE TO MATERIAL JAMMING | OPERATION REQUIREMENT POSITION INDICATION BYPASSED IN I/O RACK | 11:30:00                         | 11:45:00                         |         |
| 4     | OHP  | CC-37 SCR-7    | REPORTED SLEW NOT WORKING CHECKED AND FOUND OIL LOW LEVEL    | INFORMED TO MECHANICAL                                         | 07:10:00                         | 07:20:00                         |         |
| 5     | CHP  | CC-51          | OLR ACTED                                                    | RESET DONE                                                     | 09:40:00                         | 09:45:00                         |         |
| 6     | CHP  | CC-40 S-1      | LUFF NOT WORKING CHECKED MPCB TRIP                           | MADE ON                                                        | 07:10:00                         | 07:40:00                         |         |
| 7     | CHP  | CC-31 SCR-4    | REPORTED SLEW NOT WORKING CHECKED AND FOUND POWER MCCB TRIP  | MADE ON THAN OK                                                | 07:15:00                         | 07:30:00                         |         |
| 8     | CHP  | CC-36 SCR-1    | REPORTED PCRD CABLE FALLEN DOWN                              | PCRD CABLE PROPER LAYING WAS DONE                              | 09:45:00                         | 10:00:00                         |         |
| 9     | WT   | OT-1           | DRIVE -1 TRIP                                                | RESET DONE                                                     | 12:20:00                         | 12:25:00                         |         |