



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/07/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-16	BRS BYPASS REQUEST DUE TO LAYER PIECE	BYPASSED IN CJB	08:00:00	08:10:00	
2	OHP	CO-26 WBR	SLEW DRIVE TRIPPED IN OL	RESET DONE	07:05:00	07:25:00	
3	OHP	CO-35	TRIPPED ON OLR	RESET DONE	09:25:00 09:55:00	09:30:00 10:00:00	
4	CHP	CC-105 SCR-10	BC AND BW STOPPING DUE TO SIGNAL MISSING	LT DONE FROM TAIL END TO MIDDLE	07:15:00	08:00:00	
5	CHP	CC-33 SCR-4	SLEW NOT WORKING	30 DEGREE LIMIT ACTED	11:30:00	11:50:00	
6	CHP	CC-201	TRIPPED DUE TO OVER LOAD	RESET DONE	08:20:00	08:30:00	
7	CHP	CC-125	TRIPPED ON OLR	RESET DONE	11:40:00	11:50:00	
8	WT	OC-17A WBR	YARD TO BC ZSS CAGE STUCK	MADE FREE	11:30:00	11:40:00	
9	WT	OC-19A	BRS ACTED	RESET AFTER SENSOR CLEANING	11:20:00	11:40:00	