



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 01/08/2025

Area: WT

Equipment	Job
OP 9	New LOTUS Modem/Antenna installed both sides pusher and OT 5 ,found communication is OK
OT 5	I/O panels blowing done
CP 3	Bottom C and U clamps replaced and Trolley line inspection done, col no 39 bottom bus bar adjusted
CP 1	Panel and motor side ppm done
OP 2,5 ,7 and 9	after rake maintenance done
CP 1 and 3	After rake maintenance done