



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 27/12/2025

Area: CHP

Equipment	Job
Misc	Yard conveyors chute vibrators running condition checked and defects noted
CC-47,48 WALK WAY lighting	Slope area 30w led 3no's arranged
CC-201,CC-203,CC-222,CC-223 BELT SCALE	Belt scale units blowing done
JH-209 SUMP PUMP	Failed motor removed and spare motor fixed and made ok
LC-14,CM-15 PLC	Profibus cables changed for redundant line and made ok
RG building Lighting	screen area, feeder area and ground floor 3no's HPSV lights arranged
CC-52,VS-1,VF-1,VF-30	ppm work done
CC-7,8,9 LIGHTING	Takeup area one led light arranged
CC-25 and CC-26 LIGHTING	Tail end area lighting improved
CC-26A and CC-27A LIGHTING	Gallery bay lights arranged