



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/05/2025

Shift: B

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO29	OLR acted	Reset done	16:00:00	16:15:00	
2	OHP	BRC on CO32	BC drive over load acted	Reset done	21:45:00	22:00:00	
3	OHP	RSCO6A	Control cable loose	Tightened then ok	20:15:00	21:00:00	
4	OHP	CO35	Over load acted 2 times	Reset done	18:30:00	18:40:00	
5	OHP	CO34	Electronic olr acted	Reset done	21:20:00	21:30:00	
6	OHP	BRC on CO28	Bridge conveyor not working due to Chute jam	Jam cleared reset done then ok	17:00:00	17:20:00	
7	OHP	Stacker on CO20	Luffing not working limit acted	Limit released then ok	17:20:00	17:30:00	
8	OHP	CC112	Red found MPCB tripped	Made on	16:00:00	16:30:00	
9	CHP	CC131	Tripped on OLR	Reset done	21:20:00	21:25:00	
10	CHP	CC32	HT power made of for mechanical requirement	After completion of work HT power made on	14:50:00	16:00:00	
11	CHP	SCR8 on CC112	BW stopping frequently found float switch problem eed back not coming in XMD panel	Given high to R10	19:30:00	19:45:00	
12	CHP	CC47	ZSS acting frequently found return core problem	Core tightened then ok	19:44:00	20:15:00	
13	CHP	SCR3 on CC38	LT not working found MPCB9 tripped and in drive fault (OVA)	Out put cable removed for MPCB9 Reported to C shift	16:15:00	17:00:00	
14	WT	OP5	Not moving found over load tripped during coupling	Reset done	15:30:00	15:40:00	