



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 07/10/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-10A	OLR ACTED	RESET DONE	22:10:00	22:15:00	
2	OHP	CO-61	OLR ACTED	RESET DONE	00:05:00	00:15:00	
3	OHP	CO-26	OLR ACTED	RESET DONE	03:30:00	03:40:00	
4	OHP	WOBR- ON CO-29	SLEW NOT WORKING FOUND OLR-2 ACTED	RESET DONE	03:30:00	03:50:00	
5	OHP	CO-35	OLR ACTED	RESET DONE	03:35:00	03:45:00	
6	CHP	CC-51	MPD TRIP FEEDING CONVEYOR (25TIMES)	RESET DONE	23:15:00	23:20:00	BETWEEN 23:15 TO 06:00 AM
7	CHP	CC-34 SCR-2	B/C NOT RUNNING CHECKED AND FOUND NO PROBLEM	WRONG COMPLAINT	23:50:00	00:00:00	
8	CHP	CC-33	OLR ACTED	RESET DONE	00:10:00	00:20:00	
9	CHP	CC-33 SCR-5	REPORTED LT NOT TAKING PLACE DRIVE TRIP	RESET DONE	02:00:00	02:15:00	
10	CHP	CC-32 R-1	B/C NOT RUNNING CHECKED AND FOUND OPERATOR CABIN SIDE E/STOP ACTED	RELEASED THAN OK	02:10:00	02:30:00	
11	CHP	CC-108	MOTOR MPD-OLR TRIP	RESET DONE	04:00:00	04:10:00	
12	CHP	CC-33 SCR-5	AGAIN LT NOT TAKING PLACE CHECKED AND FOUND DRIVE TRIP OCC SHORT CIRCUIT FAULT	OLD DRIVE REMOVE AND INFORMED TO G,SHIFT	02:55:00	06:00:00	
13	WT	OT-1	DRIVE-1 PGF1 FAULT TRIP (2TIMES)	RESET DONE	23:00:00 23:25:00	23:10:00 23:30:00	