



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/11/2025

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 26 LT	TRACK JAMMING	INFORMED TO OPRN	07:00:00	07:20:00	
2	OHP	CO 29	OLR ACTED	RESET	07:30:00	07:40:00	
3	OHP	CO 67	OLR ACTED	RESET	07:00:00	07:10:00	
4	OHP	TT3 LT NOT TAKING PLACE	MPCB TRIPPED	RESET	12:10:00	12:25:00	
5	OHP	CC 28	OLR ACTING DUE TO JAMMING	RESET AND INFORMED OPRN FOR CLEANING	12:30:00	12:40:00	
6	CHP	CC 131	OLR ACTED DUE TO TAIL PULLEY JAMMING	RESET	11:10:00	11:15:00	
7	CHP	CC 132	OLR ACTED	RESET	13:00:00	13:15:00	
8	CHP	CC 54	OLR ACTED	RESET	10:00:00	10:40:00	7 TIMES
9	CHP	CC 51	FEEDING CONV MPD TRIPPED	MADE IT ON	08:55:00 10:30:00	09:00:00 10:35:00	
10	CHP	CC 51	OLR ACTED	RESET	10:20:00	10:30:00	
11	CHP	CC 125	R PHASE LUG LOOSE, TAIL END FULL JAMMING	NEW LUG REPLACED AND INFORMED OPRN TO CLEAN	06:00:00	07:20:00	
12	CHP	S3 ON CC 112 LT	DRIVE TRIPPED ON OLR	RESET	12:00:00	12:15:00	
13	WT	OT4	DRIVE 1 TRIP	RESET	09:40:00	09:45:00	