



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 14/06/2025

Area: IOSA

Equipment	Job
BLENDER RECLAIMER	SLEVE AT LUGS IN SLIP RING CHANGED BY DNW. TERMINATION DONE AND CLEARANCE GIVEN AFTER TRIAL RUN
OC-21A T/E	PPM DONE ON PANEL AND MOTOR OF VENTILLATION SYSYTEM.
OC-19A	PPM DONE ON PANEL AND MOTOR OF VENTILATION SYSTEM AT OC-19A
OC-18A	PPM DONE ON FIELD DEVICES
BLENDER RECLAIMER	PPM DONE ON MCC PANEL AND OPERATOR CONTROL DESK.