



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 22	LT not working,M1 OLR acted ,due to jamming	reset,informed operation	18:12:00	18:19:00	
2	OHP	WOBR on CO 29	LT not working,Neutral loop cable loose connection,drive f/b to PLc fuse blown	neutral connected tightly, fuse replaced	14:45:00	16:42:00	
3	OHP	wobr on CO 25	LT not working,drive tripped	reset	21:35:00	21:50:00	
4	CHP	cc 19	olr acted	reset	18:00:00	18:10:00	