



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/01/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 28 B/W 2	ZSS PROBE PROBLEM	BYPASSED	18:00:00	18:15:00	
2	OHP	CO 26	OLR ACTED	RESET	20:20:00	20:30:00	
3	CHP	CC 35	OLR ACTED	RESET	14:20:00	14:30:00	
4	CHP	CC 108	OLR ACTED	RESET	17:20:00	17:25:00	
5	CHP	SCR 7 ON CC 37 SLEW	BREAK FAIL ALARM ACTED	RESET	19:45:00	19:55:00	
6	CHP	CC 29	OLR ACTED	RESET	17:30:00 21:20:00	17:40:00 21:30:00	
7	CHP	CC 131	OLR ACTED	RESET	14:30:00 18:00:00	14:35:00 18:05:00	
8	CHP	CC 113A	OLR ACTED	RESET	14:50:00	15:00:00	
9	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	14:30:00	21:30:00	8 TIMES
10	IOSA	BRC CT	EMERGENCY ACTED	RELEASED	15:20:00	15:30:00	