



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/07/2025

Area: IOSA

| Equipment | Job |
|-------------|---|
| MANUAL YARD | LIGHTING DEFECTS RECTIFIED AND REPLACED DEFECTIVE LIGHT FITTING. |
| TBS | PCRD CHAIN TENSIONING UNIT BROKEN . TRIAL RUN TAKEN AFTER RECTIFICATION |
| OC-37A | PPM DONE ON MOTOR AND FIELD DEVICES. SPARE MOTOR MAINTENANCE DONE. |