



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 27/04/2025

Area: WT

Equipment	Job
OT 4	hooter PB shifted to center control desk
	control circuit in L C -2B , change over to P L C,wiring done accordingly and tested
OT 3 series	panel and motor side ppm done
CP 2	panel and motor side ppm done
MIS	OP1 /D6 motor coupling removed
	after rake maintenance done

OP 5 & 6

OP 2,4,7,CP1 &2