



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/01/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 15	timer acted thats why electrical complaint given by operation i/c	checked and found belt is slipping when given command in PLC,kept in local and run then its run	00:57:00	02:30:00	not an electrical problem,stream changed @0115am and again given @02.30 am
2	OHP	co 14	zss acted,belt movement slow	mechanical and operation problem	04:00:00	04:20:00	
3	OHP	TT1	cjd acted,jamming was there	informed operation but not accepted,show them photo,than accepted	03:50:00	04:10:00	
4	OHP	co 25	OLR acted	reset	03:10:00	03:15:00	
5	OHP	CO 26	OLr acted	reset	02:45:00	02:55:00	
6	OHP	wobr on co 25	slew not working,olr acted	reset	05:30:00	05:45:00	
7	OHP	VS 1A	olr acted	reset	04:20:00	04:30:00	
8	CHP	CC 51	mpd acted	reset	23:30:00	23:35:00	10 times
9	CHP	CC 114	olr acted	reset	00:30:00	00:40:00	