



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/02/2026

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	TRIPPED ON OLR (2TIMES)	RESET DONE	07:20:00 11:30:00	07:30:00 11:40:00	
2	OHP	TBS ON CO-24	REPORTED B/C NOT RUNNING FOUND BOTH B/C DRIVES POWER AND CONTROL OFF CONDITION	MADE ON THAN OK	07:50:00	08:00:00	
3	OHP	WOBR ON CO-25	REPORTED LT NOT TAKING PLACE FOUND M-2 OLR ACTED	RESET DONE	13:25:00	13:35:00	
4	CHP	CC-18	REPORTED STOPPING ON ZSS CHECKED AND FOUND ZSS CAGE STUCK UP WITH COAL PICK	REMOVED THAN OK	11:15:00	11:25:00	
5	CHP	CC-54	OLR ACTED (2TIMES)	RESET DONE	07:40:00 08:20:00	07:45:00 08:25:00	
6	CHP	CC-113A	OLR ACTED DUE TO JAMMING	RESET DONE	11:10:00	11:15:00	
7	CHP	CC-51	MPD TRIPPED	RESET DONE	08:40:00	08:45:00	
8	CHP	VF-3	OLR ACTED	RESET DONE	11:50:00	11:55:00	
9	CHP	CC-33 S-3	B/C OLR ACTED	RESET DONE	08:05:00	08:15:00	
10	CHP	CC-125	OLR ACTED	RESET DONE	08:15:00	08:20:00	
11	CHP	CC-39 SCR-6	REPORTED LT NOT TAKING PLACE M-4 OLR ACTED	RESET DONE	09:20:00 09:50:00	09:30:00 10:00:00	
12	CHP	CC-216	OLR ACTED	RESET DONE	09:20:00	09:35:00	
13	CHP	CC-108	OLR ACTED	RESET DONE	10:10:00	10:15:00	
14	CHP	CC-201	OLR ACTED	RESET DONE	10:30:00	10:35:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/02/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC-32 SCR-5	REPORTED B/C NOT RUNNING NO PROBLEM	WRONG COMPLAINT	12:55:00	13:05:00	