



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/12/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 50	olr acted	reset	20:45:00	20:55:00	
2	OHP	BRC on CO 32	Bw not running, control MCB tripped	made it on	18:20:00	18:30:00	
3	OHP	TBS on CO 22	LT not working, M4 motor tripped	olr reset	16:50:00	17:00:00	
4	OHP	CO 85	olr acted	reset	18:40:00	18:45:00	
5	CHP	CC 105 SCR10	LT not working, found lt in inch mode	LT put in normal	16:45:00	17:00:00	
6	CHP	CC 35 SCR3	LT not working, drive tripped	reset	20:30:00	20:45:00	
7	CHP	cc 114	OLR ACTED	reset	18:25:00	18:35:00	
8	CHP	CC 117	olr acted	reset	15:15:00	15:30:00	
9	CHP	CC 131	olr acted	reset	17:10:00	17:15:00	
10	CHP	CC 132	olr acted	reset	21:45:00	21:50:00	
11	CHP	CC 130	healthy stop, mech brs just touch and go because of belt piece hanging	informed mech, mech cut the piece	18:25:00	18:30:00	
12	WT	CO 4(C)	mpcb tripped	made it on	16:30:00	16:40:00	
13	WT	OT1	D1 TRIPPED IN PGF1 FAULT	RESET	21:35:00	21:45:00	