



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 09/08/2025

Area: OHP

Equipment	Job
CO 50 51 53 56 57 WF 2 3 4 5	PPM BOTH MOTOR AND PANEL SIDE PPM
CC 109	HOIST MAINTENANCE DONE
JH5	LDB MAINTAINANCE, ONE LIGHT GIVEN AT STAIR CASE AREA
CC 27A TT	PPM DONE
CO 17	PPM DONE
BRC ON CO 31	CJD KEPT IN CIRCUIT
TBS 1 ON CO 20	CONTROL ON and OFF PROVIDED FROM OPERATOR CABIN
CO31A, 33A, 35A, 37A	FIELD DEVICES PPM DONE