



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/08/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-26	SLEW NOT MOVING CHECKED AND FOUND DRIVE TRIPPED(2TIMES)	RESET DONE	16:30:00 17:30:00	16:50:00 17:40:00	
2	OHP	WOBR ON CO-26	SLEW NOT WORKING DRIVE TRIP	SLEW SPEED DECREASED WITH POTENTIOMETER AND DRIVE RESET DONE	18:00:00	18:20:00	
3	OHP	CO-84	REPORTED RED CHECKED AND FOUND OLR ACTED (2TIMES)	RESET DONE	17:50:00 19:00:00	18:00:00 19:10:00	
4	OHP	CO-35	RED CHECKED AND FOUND OLR ACTED	RESET DONE	19:10:00	19:20:00	
5	OHP	BRC ON CO-28	B/C NOT RUNNING CHECKED AND FOUND OLR ACTED	RESET DONE	20:15:00	20:30:00	
6	OHP	WOBR ON CO-25	B/C STOPPING ON ZSS CHECKED AND FOUND ZSS CAGE STUCK UP WITH STONE	STONE REMOVED AND TESTED OKAY	20:15:00	20:30:00	
7	OHP	CC-58 TT	FESTOON CABLE DAMAGED	JOINT DONE THEN OK	15:25:00	16:00:00	
8	OHP	CO-113	Reported not healthy	MCCB tripped.Made on	21:15:00	21:20:00	Due to over material on belt
9	CHP	CC-104 SCR-9	LT NOT TAKING PLACE CHECKED AND FOUND FAULT RESET NOT PRESSED	FAULT RESET DONE AND TESTED OKAY	16:10:00	16:25:00	
10	CHP	CC-34 SCR-2	LT NOT TAKING PLACE O/T ACTED	O/T RELEASED THAN OK	16:10:00	16:20:00	
11	CHP	CC-51	OLR TRIP (3TIMES)	RESET DONE	16:15:00 17:20:00 21:10:00	16:25:00 17:25:00 21:20:00	
12	CHP	CC-54	OLR ACTED	REST DONE	18:05:00	18:10:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/08/2025

Shift: B

Incharge(s): Amit Roy, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-113	STOPPING ON ZSS	DUE TO MATERIAL JAMMING	18:20:00	18:25:00	INFORMED TO OPERATION
14	CHP	CC125	Reported not healthy	OLR acted.reset done	21:30:00	21:35:00	