



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/02/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS 1A	OLR ACTED	RESET	00:25:00	00:35:00	
2	CHP	CC 27A ZSS ACTING	PROBE CLEANED	THEN OK	22:10:00	22:20:00	
3	CHP	CC 222	EMERGENCY ACTED	RELEASED	23:30:00	23:45:00	
4	CHP	SCR 7 ON CC 34	ACB IS IN OFF CONDITION	MADE IT ON	02:30:00	02:45:00	
5	CHP	SCR 7 ON CC 34 LT	PCRD O/T ACTED	RELEASED	03:50:00	04:00:00	
6	CHP	SCR 4 ON CC 31 B/C	CHUTE SENSOR ACTED	AFTER CLEANING OK	04:10:00	04:30:00	
7	CHP	SCR 4 ON CC 31 B/C	COMMUNICATION PROBLEM	LT DONE THEN OK	04:45:00	05:00:00	
8	CHP	CC 54	OLR ACTED	RESET	02:40:00 03:40:00	02:50:00 03:45:00	
9	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	01:20:00 01:40:00	01:30:00 01:45:00	
10	CHP	CC 131	OLR ACTED	RESET	01:40:00	01:45:00	
11	WT	OP5	HEALTHY RELAY COIL SUPPLY LOOSE	TIGHTENED THEN OK	04:20:00	04:40:00	
12	WT	OP5	DRIVE 4 OLR ACTED	RESET	05:50:00	06:00:00	