



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/05/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 6A	Overload acted	reset done	15:05:00	15:15:00	
2	OHP	CO 57	Stopped on pull chord	reset done	16:15:00	16:30:00	
3	OHP	TBS on CO 20	Left Luff not working	Limit switch tied up , made free	16:15:00	17:00:00	
4	OHP	CO 33M	Pump not starting due to oil level low signal not coming	Sensor problem, bypassed as per instrumentation instruction	17:30:00	18:00:00	kept in circuit after sensor cleaning
5	CHP	CC 104	Emergency push button acted	In IO rack termination loose , after re termination healthy	15:00:00	15:15:00	
6	CHP	CC 40 , SCR 6	LT not working due to PCRD overtension	Overtension released	17:20:00	17:30:00	
7	CHP	CC 104, SCR 9	LT not working due to PCRD overtension	Overtension released.	17:00:00	18:00:00	
8	CHP	CC 54	Tripped in overload	reset done	17:15:00	17:20:00	
9	CHP	CC 131	Tripped in overload	reset done	16:40:00 20:10:00 21:20:00	16:45:00 20:15:00 21:25:00	
10	CHP	CC 52	Stopped on ZSS	Due to load on belt	18:30:00	20:00:00	
11	WT	OP 1	Breaker tripped	Made ON and tested	14:30:00	14:45:00	Column no 74,75