



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/10/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	00:50:00 23:00:00	00:55:00 23:10:00	
2	OHP	TBS ON CO-19	LT M2 MOTOR TRIPPED PCRD OT ACTED	RESET DONE RELEASED	03:00:00 23:50:00	03:20:00 00:05:00	
3	OHP	BRC ON CO-28	LT M1 TRIPPED DUE TO TRACK JAMMING	RESET DONE	02:40:00	03:00:00	
4	CHP	CC-107	TRIPPED ON OLR	RESET DONE	04:05:00	04:15:00	
5	CHP	CC-38 SCR-6	LT DRIVE TRIPPED	RESET DONE	04:00:00	04:15:00	
6	WT	OP-6	COLUMN 31 TOP PAD FALLEN C AND U CLAMP BEND	RECTIFIED	22:00:00	23:30:00	NO RACK
7	WT	OT-5	D-2 SIDE ENCODER PROBLEM	CHANGED AND TESTED	22:30:00	00:00:00	NO RACK