



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/07/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT 2	PCRD mpcb tripped	made on	16:30:00	16:40:00	
2	OHP	CO 22 TBS	LT LUFF BC not running	LUFF and BC overload acted, reset done. LT brake adjusted by mechanical	18:00:00	18:20:00	
3	OHP	CO 35	OLR acted	reset done	17:50:00	17:55:00	
4	CHP	CC 32 , SCR 5	BC not running due to OLR acted	reset done	14:10:00	14:25:00	
5	CHP	CC 40 , SCR3	BC signal missing	LT done	17:00:00	17:15:00	
6	CHP	CC 105 , SCR 7	Slew not running	Charge pressure alarm , reset done	18:55:00	19:15:00	
7	CHP	CC 105 , SCR 7	BC signal missing	LT done	20:20:00	20:50:00	
8	CHP	CC 36 , S 2	PCRD gearbox problem	Cable drum arrested on mechanical request . Informed to operation and mech	17:30:00	17:45:00	
9	CHP	CC 22	Carriage drive tripped	reset done	14:50:00	15:00:00	
10	CHP	CC 24	Carriage drive tripped	Reset done . One phase loose , tightened	15:00:00	15:10:00	
11	CHP	CC 54	OLR acted (5 times)	reset done	15:40:00	18:15:00	
12	WT	CO 2	Belt drive overload acted	reset done	16:00:00	16:10:00	
13	WT	CP 3	ACB in OFF condition	made on	18:20:00	18:40:00	C clamp , U clamp with jumper replaced after rake



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/07/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OP 2	D 1 overload acted	reset done	21:00:00	21:10:00	