



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/12/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 67	tripped on olr	reset done	06:30:00	06:40:00	
2	CHP	scr 1 on cc34	It not taking place/m2 mpcb tripped	made on	08:20:00	08:30:00	
3	CHP	r1 on cc33	bc not running/interlock cage stuckup with material	cage made free.then ok	10:58:00	11:10:00	
4	CHP	s2 on cc36	slew not working/30degree limit acted	limit released then ok	11:30:00	11:40:00	
5	CHP	cc19	tripped on olr	reset done	10:20:00	10:30:00	
6	CHP	cc51	mpd tripped	reset done	08:55:00	12:50:00	6times
7	CHP	cc54	tripped on olr	reset done	13:25:00	13:30:00	
8	CHP	cc 114	tripped on olr	reset done	09:35:00	09:40:00	
9	CHP	cc117	tripped on olr	reset done	12:10:00	12:25:00	
10	WT	op 5	not moving/ AL relay stuckup/made free	tested ok	11:30:00	11:40:00	