



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	TRIPPED ON OLR	RESET DONE	02:15:00 03:10:00	02:25:00 03:20:00	
2	OHP	CO-29	TRIPPED ON OLR	RESET DONE	02:20:00 04:40:00	02:30:00 04:45:00	
3	OHP	CO-111	MPCB TRIPPED	MADE ON	02:15:00	02:25:00	
4	OHP	CO-67	TRIPPED ON OLR	RESET DONE	02:50:00	03:00:00	
5	OHP	TBS ON CO-21	LT NOT WORKING	M1 TRIPPED ON OL ... RESET DONE	05:10:00	05:25:00	
6	CHP	cc-51	MPD TRIPPED	RESET DONE	23:30:00	05:30:00	15 TIMES
7	CHP	CC-105 SCR-10	SLEW NOT WORKING DUE TO DRAIN FILTER PROBLEM	CHANGED TO SPARE DRAIN FILTER THEN OK	22:40:00	22:50:00	
8	CHP	CC-31 SCR-4	LT NOT WORKING	DRIVE TRIPPED ... RESET	03:40:00	03:55:00	
9	CHP	CC-125	TRIPPED ON OLR	RESET DONE	05:15:00	05:20:00	
10	IOSA	BRC	CT OVER TRAVELED LIMIT STUCK	MADE FREE AND TESTED	02:15:00	02:40:00	