



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

#### ELECTRICAL SHIFT REPORT

Date: 14/07/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED(2TIMES)	RESET	04:00:00	04:30:00	
2	OHP	TT 4	TT NOT MOVING MPCB TRIP	RESET	04:45:00	05:00:00	
3	OHP	RSCO 1A	STOPPING ON ZS ZS PROBE LOOSE	TIGHTEN THAN OK	05:15:00	05:40:00	
4	OHP	CO 13 (C) DRIVE	OLR ACTED	RESET	05:30:00	05:45:00	
5	OHP	WOBR ON CO 6A	B/W STOPPING OIL LOW LEVEL SHOWING	IN FORMED TO MECH	04:15:00	04:40:00	
6	OHP	TBS ON CO 22	LT NOT TAKING PLACE CHECKED SELECTOR IN LOCAL MODE	KEPT IN REMOTE THAN OK	05:30:00	05:40:00	
7	CHP	CC 51A	OLR ACTED(2TIMES)	RESET	03:40:00	03:55:00	
8	CHP	CC 103 ON TT	LT NOT TAKING PLACE CHKED OLD JOINT OPEN	TEMPRARY JOINT DONE	02:10:00	03:00:00	
9	CHP	OLD CCR	PLC room ac mcb trips	made it on	22:25:00	22:35:00	
10	CHP	CC 105	yard conveyor not healthy,shutdown tag was there	shutdown normalize	23:30:00	23:37:00	
11	CHP	SCR 10 on CC 105	B/C not running,mcb trips not getting on,earth fault,	field wire removed than mcb hold,than contactor not getting on even command is reached upto X1-8,9 ..loop given from x1 8 to x1-23 and x1-9 to x1 -25 and clearance given	00:20:00	02:45:00	
12	CHP	CC 33 scr 4	LT not working,drive trips in overload	reset	02:00:00	02:10:00	
13	CHP	CC 40 SCR 6	LT not working,drive trips in overload	reset	01:25:00	01:35:00	