



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/02/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-33M	OLR ACTED	RESET DONE	08:25:00	08:30:00	
2	OHP	BRC ON CO-32	REPORTED B/W-1 NOT RUNNING FOUND THRUST ROLLER PROBLEM	INFORMED TO OPERATION	08:20:00	08:40:00	
3	OHP	RSCO-10A	REPORTED NOT HEALTHY CHECKED AND FOUND 1-141LC-3 I/C-1 TRIPPED U/V FAULT	FAULT RESET AND I/C-1 CHARGED THAN OK	10:30:00	10:40:00	
4	OHP	CO-5A	BRS ACTED FREQUENTLY	SENSORS CLEANED THAN OK	07:15:00	07:30:00	
5	OHP	CO-29	REPORTED P/C NOT HEALTHY FOUND GLASS FUSE BLOWN	GLASS FUSE RE-PLACED THAN OK	11:50:00	12:05:00	
6	OHP	CC-40 SCR-2	LUFFING NOT WORKING FILTER CLOGGED-3 NOT HEALTHY	BY PASSED INFORMED TO MECHANICAL	11:00:00	11:15:00	
7	CHP	CC-131	OLR ACTED	RESET DONE	10:00:00	10:10:00	
8	CHP	CC-203	CHUTE FULL ACTED	RELEASED THAN OK	06:20:00	06:30:00	
9	CHP	CC-40 SCR-2	TUL C/S ACTED POBE CABLE GOT CUT	JOINT DONE THAN OK	06:45:00	07:00:00	
10	CHP	CC-39 SCR-6	LT NOT TAKING PLACE	FAULT RESET THAN OK	08:40:00	08:50:00	
11	CHP	CC-104 SCR-7	REPORTED SLEW AND B/W NOT RUNNING B/W STUCK UP IN MATERIAL	LT REVERSE THAN OK	09:45:00	10:00:00	
12	CHP	CC-40 SCR-2	ALL DRIVES NOT RUNNING MAIN OFF CONDITION	MAIN ON THAN OK	10:00:00	10:10:00	
13	CHP	CC-34 SCR-1	LUFF NOT WORKING OLR ACTED	RESET DONE THAN OK	11:55:00	12:10:00	