



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/06/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR acted	reset done	09:30:00	09:40:00	
2	OHP	CO 29	OLR acted	reset done	09:35:00	09:45:00	
3	OHP	CO 5	BRS bypass request from operation	Bypassed AT CJB	08:00:00	08:15:00	
4	OHP	SB 2A Bunker	Bunker level to bypass on operation request	bypass done at IO rack	12:40:00	12:55:00	
5	OHP	WOBR on CO 6A	LT not taking place due to overtension acted	tension released	11:25:00	11:40:00	
6	CHP	CC 131	Tripped in overload ( 3 times)	reset done	07:30:00	13:30:00	
7	CHP	CC 104 , SCR 9	OHP side boom position bit not coming	Bypassed in IO rack	12:30:00	12:45:00	
8	CHP	CC 35 , SCR 2	LT not working due to pcrd overtension acted ( 2 times)	Overtension released	12:50:00	13:25:00	
9	CHP	CC 38 , SCR 3	Luff up to be done due to jamming	bypass done . Again removed	06:50:00	07:05:00	
10	CHP	CC 125	OLR acted	reset done	13:40:00	13:45:00	
11	CHP	CC 31	ZSS probe problem	ZSS bypassed in IO rack	13:20:00	13:30:00	Probe change job going on
12	WT	OP 8	Drive 4 tripped in SL3HF fault	reset done	09:55:00	10:10:00	
13	WT	OP 1	Drive 2 tripping	Motor burn, motor isolated and declutched	13:30:00	13:50:00	