



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 27/01/2026

Area: WT

Equipment	Job
CP 3 jobs	control cable laying done from main panel to drive panels for out put
CP 3 jobs	D 5 and 6 Motor termination done
CP 3 jobs	L H S , D B R termination and cable dressing done
CP 3 jobs	R H S , D B U and D B R fixing done
OP 1	B-phase O/G terminal bolt replaced in LC 2A panel
OP 1	D6 Motor removed from bed for mechanical/gear box job
OP 1,2,3,4,5,6 and 10	After rake maintenance done