



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/02/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	OLR ACTED	RESET	14:00:00	14:10:00	
2	OHP	CR 2	LUBRICATION PUMP1 not running,lub oil flow not ok	RESET	15:45:00	15:55:00	
3	OHP	CO 29	P/C acted	released	18:10:00	18:20:00	
4	OHP	CO 34	OLR acted	reset	20:00:00	20:10:00	
5	CHP	CC 39 scr 6	no power in M/C,no power in isolator	PNL 13 of LBDS 5 not getting on tripped in VAJ fault ,PNL27 made on and one by one made on CC 39 and CC 40 I/O side CC 39 get on given clearance 6.35 PM	18:00:00	18:30:00	@8.00 PM fault(VAJ) get reset of PNL 13 of LBDS5 and made on.Now both PNL 13 and 27 is in on in LBDS5
6	CHP	CC 40 SCR2	no power,fault is there in SCR 2on CC 40 cable,FDR in LBDS 5 got tripped immediately	fuse checked all ok,megger done after opening coupler side and slipping side,two no of core not fount continuity	18:00:00	19:20:00	informed DNW,
7	CHP	CC 51	MPD acted	reset	14:30:00	14:35:00	
8	CHP	CC 117	motor tripped 2 times	reset	17:00:00	17:05:00	
9	WT	CP 3	no movement,emergency acted	released	15:30:00	15:40:00	operation delay
10	WT	CO 4(C)	mpcb tripped	made on	21:30:00	21:35:00	