



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/05/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|-----------------------|----------|----------|---------|
| 1 | OHP | WOBR ON CO 25 | B/C NOT RUNNING ZS CAGE STUCK WITH STONE | REMOVED | 07:45:00 | 08:00:00 | |
| 2 | OHP | CO 35 | OLR ACTED | RESET | 08:00:00 | 08:15:00 | |
| 3 | OHP | CO 51 | STOPPING ON ZS BELT OFFCENTRING | INFORMED TO OPERATION | 07:00:00 | 07:15:00 | |
| 4 | CHP | CC 117 | OLR ACTED | RESET | 08:10:00 | 08:15:00 | |
| 5 | CHP | CC 44 | OLR ACTED | RESET | 13:30:00 | 13:35:00 | |
| 6 | CHP | CC40 SCR 6 | TUL C/S NOT WORKING PROBE WIRE GOT CUT | JOINT DONE | 07:15:00 | 07:35:00 | |
| 7 | CHP | CC40 | OLR ACTED | RESET | 10:00:00 | 10:15:00 | |
| 8 | CHP | CC 107 | BRS NOT WORKING | SENSORS CLENED OK | 11:00:00 | 11:15:00 | |