



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	DB1	olr acted,	reset	09:00:00	09:15:00	
2	OHP	CO 67	olr acted	reset	12:05:00	12:15:00	
3	OHP	BRC on co 28	OLR acted	reset	09:10:00	09:20:00	
4	OHP	BRC on CO 8A	b/w stopping on zss fault,zss fault	zss probe replaced	09:30:00	10:15:00	
5	OHP	CO 26	OLR acted	reset	11:35:00	11:40:00	
6	OHP	BRC on CO 34	pcrd motor not running,y phase cable cut near tb	y phase cable jointed,than found that control side FWD contactor output cable tightened	08:00:00	08:45:00	
7	CHP	CC 54	olr acted	reset	12:40:00	12:45:00	
8	CHP	CC 51	mpd trips due to overload	made it on	07:20:00	07:25:00	
9	CHP	CC 33 scr 5	olr acted	reset	07:15:00	07:25:00	
10	CHP	CC 33 scr 5	LT not working	wrong complaint	07:35:00	07:45:00	
11	CHP	CC 35 scr 3	luffing not working,luff down limit acted	ls released than o0k	09:50:00	10:00:00	
12	CHP	CC 33 SCR 5	LT not working,pcrd guide problem	informed to mech	12:00:00	12:10:00	
13	CHP	CC 112 SCR8	b/c not running,zss acted	fault reset done than ok	13:50:00	13:55:00	
14	WT	Sco 1A(C)	mpcb tripped	made it on	10:00:00	10:05:00	