



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/07/2025

Shift: B

Incharge(s): Amit Roy, K SANKARA RAO

| Sl No | Area | Equipment     | Problem                          | Action  | From     | To       | Remarks                            |
|-------|------|---------------|----------------------------------|---|----------|----------|------------------------------------|
| 1     | OHP  | wobr on co 26 | slew not taking place drive trip | drive reset   | 19:45:00 | 20:00:00 |                                    |
| 2     | OHP  | brc on co 33m | b/w 1 not running                | fault reset than ok                                 | 16:30:00 | 16:45:00 |                                    |
| 3     | OHP  | vs-2          | Reported not healthy             | OLR acted.Reset done                                | 21:45:00 | 21:55:00 |                                    |
| 4     | OHP  | CO-26         | Reported not healthy             | OLr acted. reset done                               | 21:45:00 | 21:55:00 |                                    |
| 5     | CHP  | cc 51a        | olr acted(4times)                | olr reset   | 17:05:00 | 20:50:00 | due to material over load          |
| 6     | CHP  | cc-54         | olr acted                        | olr reset   | 14:50:00 | 15:00:00 |                                    |
| 7     | CHP  | CC-105 SCR 7  | Reported LT not taking place     | PCRD chain problem.Cable loop given for operation   | 14:00:00 | 15:00:00 | To be checked from mechanical side |
| 8     | CHP  | CC-104 SCR-9  | LT not taking place              | PCRD gearbox problem.Cable loop given for operation | 15:00:00 | 16:00:00 | To be checked from mechanical side |
| 9     | CHP  | CC 40 S-1     | LT not taking place              | PCRD gearbox problem.Cable loop given               | 15:15:00 | 16:00:00 | To be checked from mechanical side |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/07/2025

Shift: B

Incharge(s): Amit Roy, K SANKARA RAO

| Sl No | Area | Equipment           | Problem   | Action   | From     | To       | Remarks                  |
|-------|------|---------------------|---|--|----------|----------|--------------------------|
| 10    | CHP  | CC-44               | Reported not healthy  | OLR acted.reset done   | 17:00:00 | 17:15:00 |                          |
| 11    | CHP  | CC-38<br>SCR-3      | B/C not running   | signal missing due to plc not communicating.<br>PLC power recycled                                   | 16:00:00 | 16:35:00 |                          |
| 12    | CHP  | CC-39<br>SCR-6      | B/W not rotating  | Hose pipe damaged.   | 18:00:00 | 18:20:00 | Informed to mechanical   |
| 13    | CHP  | CC-112<br>SCR-8     | Slew not working  | OIL low level acted and charge pressure low acted.Forced in program and then removed and tested okay | 21:20:00 | 21:45:00 | Oil to be filled in tank |
| 14    | CHP  | CC-34<br>SCR-2      | Reported LT not taking place                                    | PCRD ot acted. Tension released and tested okay  | 21:00:00 | 21:20:00 |                          |
| 15    | WT   | ot-1                | initional not com checked no electrical problem                 | informed to mech   | 14:30:00 | 14:45:00 |                          |
| 16    | WT   | sco-1a (c)<br>drive | frequently olr acted checked one phase got cut in festoon cable | re joint done than ok  | 19:30:00 | 20:00:00 |                          |