



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/01/2026

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------------|---------------------------------|------------------|----------------------|----------------------|---------|
| 1 | OHP | BRC ON CO 8A | B/C OLR ACTED | RESET | 16:10:00 18:20:00 | 16:30:00 18:30:00 | |
| 2 | OHP | BRC ON CO 32 B/W | CONTROL MCB IS IN OFF CONDITION | MADE IT ON | 20:15:00 | 20:30:00 | |
| 3 | OHP | CC 25 | OLR ACTED | RESET | 21:30:00 | 21:40:00 | |
| 4 | CHP | CC 131 | OLR ACTED | RESET | 16:15:00 | 16:20:00 | |
| 5 | CHP | CC 54 | OLR ACTED | RESET | 16:45:00 | 16:50:00 | |
| 6 | CHP | CC 47 ZSS ACTING | BELT SLOW | INFORMED TO OPRN | 18:15:00 | 18:25:00 | |
| 7 | WT | CO 3 | OLR ACTED | RESET | 15:30:00 | 15:40:00 | |