



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/12/2025

Shift: A

Incharge(s): Lal Singh,Lal Singh

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---|--|----------------------|----------------------|--------------------------------|
| 1 | OHP | CC-33M | OLR ACTED | RESET DONE | 07:50:00 | 07:55:00 | |
| 2 | OHP | CO-25 | TRIPPED ON OLR | RESET DONE | 08:45:00 | 08:55:00 | |
| 3 | OHP | WBR ON CO-26 | SLEW DRIVE TRIPPED | RESET DONE | 08:45:00 | 09:00:00 | |
| 4 | OHP | WBR ON CO 25 | ZSS INTERLOCK CAGE STUCK | RELEASED | 09:15:00 | 09:30:00 | |
| 5 | OHP | CO-26 | TRIPPED ON OLR | RESET DONE | 09:45:00 12:00:00 | 09:55:00 12:10:00 | |
| 6 | OHP | CO-33M BRC | LT NOT WORKING PCRD PROBLEM | LOOP GIVEN .. MACHINE GIVEN IN RUNNING | 13:15:00 | 13:45:00 | PCRD OLR AND MCB TO BE CHANGED |
| 7 | CHP | CC-201 | TRIPPED ON OLR | RESET DONE | 06:40:00 | 06:50:00 | |
| 8 | CHP | CC-203 | TRIPPED ON OLR | RESET DONE | 06:40:00 | 06:50:00 | |
| 9 | CHP | CC-31 scr-4 | BC STOPPING ON ZSS ... PROB PROBLEM | BYPASSED AND GIVEN FOR STACKING | 08:55:00 | 09:10:00 | |
| 10 | CHP | CC-47 | STOPPING ON ZSS... BECOUSE OF OVER LOAD | INFORMED OPERATION | 11:05:00 | 11:15:00 | |
| 11 | CHP | CC 113 | OLR ACTED | RESET | 07:02:00 | 07:08:00 | |
| 12 | CHP | CC 117 | olr acted | reset | 07:55:00 | 07:59:00 | 2 times |
| 13 | CHP | CC 54 | olr acted | reset | 10:38:00 | 13:30:00 | 11 times |
| 14 | CHP | cc-38 S-1 | PCRD GUIDE PROBLEM | INFORMED MECH | 12:00:00 | 12:15:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|-------------------|----------------|----------|----------|---------|
| 15 | CHP | CC-34 SCR-1 | PCRD CABLE FALLEN | WINDING DONE | 13:15:00 | 13:25:00 | |
| 16 | WT | CO-4 | TRIPPED ON OLR | RESET DONE | 07:00:00 | 07:20:00 | |
| 17 | IOSA | HVMCC-6 | IC-1 TRIPPED | POWER RESTORED | 08:10:00 | 08:30:00 | |