



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 05/08/2025

Area: WT

Equipment	Job
MIS	18.5 KW ,spare motor tested,OK kept @ OT Complex
MIS	55 KW spare motor coupling fixed
OP 10	ether net cable replaced ,tested found OK
OT 2	M1 motor TB cover tapping and fixing done properly
CP 2 and 3	After rake maintenance done