



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/06/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO30	B/W 1 NOT RUNNING LOW OIL LEVEL IN FLUID COUPLING	INFORMED TO MECH	19:50:00	20:15:00	
2	OHP	TBS ON CO20	R/LUFF NOT TAKING PLACE UP LIMIT ACTED	RELEASED	20:00:00	20:15:00	
3	OHP	CO26	OLR ACTED(2TIMES)	RESET	20:45:00	21:30:00	
4	OHP	TBS ON CO20	LT NOT NOT TAKING PLACE O/T ACTED	RELEASED	15:15:00	15:30:00	
5	CHP	CC 117	OLR ACTED	RESET	19:00:00	19:15:00	
6	CHP	CC 36 SCr 1	slew not working,jammimg	informed operation	15:10:00	15:20:00	
7	CHP	CC 203	motor not healthy,mpd trips	reset	16:20:00	16:30:00	
8	CHP	CC 53	NOT HEALTHY E/STOP ACTED	RELEASED	18:00:00	18:15:00	
9	CHP	CC 38 scr 3	signal missing	LT done than ok	17:00:00	17:10:00	
10	CHP	CC 32 SCR 5	LT not taking place,M2 mpcb trips	made it on	18:00:00	18:15:00	
11	CHP	CC 202	remote mode not healthy,zss acted ,zss card problem	zss bypass	18:50:00	19:20:00	no spare card,to be changed in G shift
12	CHP	CC 34 SCR 2	all drive not working,neutral wire of O/p relay of PLC got burnt	neutral wire connected properly	20:00:00	21:05:00	
13	CHP	CC 33 scr 4	b/c not running,cjs acted,jammimg	informed operation	21:10:00	21:20:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/06/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	cc 32 scr 5	SLEW NOT WORKING, SLEW 30 DEGREE LIMIT ACTED	b/c STOP AND SLEW POSITION CHANGE FROM GVM SIDE TO OHP SIDE	14:30:00	14:40:00	