



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 04/07/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 31	CT NOT TAKING PLACE CT CHAIN GOT CUT	IN FORMED TO MECH	15:40:00	16:00:00	
2	OHP	CO 35	OLR ACTED	RESET	18:45:00	19:00:00	
3	OHP	RSCO 6A(BELT DRIVE)	OLR ACTED	RESET	20:15:00	20:25:00	
4	OHP	BRC ON CO 31	B/C OLR ACTED	RESET	21:20:00	21:30:00	
5	CHP	CC 131	OLR ACTED(2TIMES)	RESET	15:10:00	15:30:00	
6	CHP	CC 54	OLR ACTED (2TIMES)	RESET	19:00:00	19:20:00	
7	CHP	CC 25	STOPPING ON ZS JOD ACTED DUE TO BELT PIECE	IN FORMED TO MECH	17:50:00	18:00:00	
8	CHP	CC 33	OLR ACTED	RESET	15:30:00	15:40:00	
9	CHP	CC 33	C/S ACTED DUE TO PROBE WIRE GOT CUT	RE JOINTED THAN OK	17:00:00	17:10:00	
10	CHP	cc 39 scr 7	NO communication, PLC and Wireless not pinging, no power from lower house to antenna JB	cable trace done found wrong joint of cable near slew chamber phase and neutral shorted, cable joining done properly MOdem powered up, all communication ok	18:15:00	20:35:00	
11	CHP	CC 33	OLR acted in mpr	reset	15:30:00	15:40:00	
12	CHP	CC 35 SCR1	slew not working, M2 mpcb trip	mpcb made on	21:10:00	21:20:00	
13	CHP	CC 33 D/E	CJS acted, probe wire cut	probe wire jointed	16:00:00	16:10:00	