



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/10/2025

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-36	Reported BRS not getting reset	Checked and found BRS healthy and acting fine.Reset done	10:00:00	10:15:00	
2	OHP	CO-29	Reported emergency acted even though released	Checked and found fuse burnt in CJB.P/C earth fault.P/C bypassed,field wires removed in CJB and tested okay	08:10:00	08:30:00	P/C to be checked and to be kept in line
3	OHP	WOBR on CO-26	Reported no drives running	Checked and found slew right emergency acted. Slewing done bypassing and control made on and operations tested okay	10:15:00	10:30:00	SLew right limit switch to be checked
4	OHP	WOBR on CO-25	HT cable joint pending from C-shift	DNW did cable joint and power restored and operations tested okay	06:00:00	09:00:00	
5	OHP	CO-12(C/D)	Reported tripped	OLR acted.Reset done	09:20:00	09:30:00	
6	OHP	RSCO-10A(C/D)	Reported Tripped	OLR acted.Reset done	10:15:00	10:30:00	
7	CHP	CC-54	Reported tripped	OLR acted.Reset done(2 times)	09:45:00 11:15:00	09:55:00 11:25:00	
8	CHP	CC-131	Reported tripped	OLR acted.Reset done	07:35:00	07:40:00	
9	CHP	CC-112 SCR-8	Reported B/C signal missing and LT not moving	modem power recycled and Lt end limit bypassed and tested okay	06:35:00	07:15:00	Operation request given for Lt end limit bypass



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/10/2025

Shift: A

Incharge(s): Amit Roy, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
10	CHP	CC-112 SCR-8	Luffing not working	Oil level low.informed to mechanical	07:40:00	07:50:00	
11	CHP	CC-31 SCR-4	Reported B/W not running	Charge pressure acting frequently.Informed to mechanical	09:30:00	09:45:00	
12	CHP	CC-38 SCR-6	TUL C/S acted	Bypassed due to rain as per operation request	12:00:00	12:10:00	
13	WT	OT-1	Drive-1 tripped	PGEF fault.Reset done(2 times)	10:15:00 12:00:00	10:20:00 12:10:00	