



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 05/07/2025

Area: IOSA

Equipment	Job
LC-2	HOUSEKEEPING DONE IN FIRST FLOOR and BATTERY ROOM
OC-23A	MOTOR COVERED WITH BELT PIECE AS RAIN WATER IS FALLING ON MOTOR FROM SHED TOP.
OC-11A	PPM DONE ON MOTOR AND FIELD DEVICES .
OC-27A	LIGHTING DEFECTS RECTIFIED IN OC-27A GALLERY AND SUFFICIENT LIGHT FITTINGS ARRANGED.