



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/09/2025

Area: WT

| Equipment    | Job  |
|--------------|--|
| SCO 1A       | Field control cable checked ,found earth fault in Belt Way switch,isolated it. |
| OC1A level   | Lighting job done ,50 W LED bulbs 2 nos replaced                               |
| OP 3,4 and 6 | After rake maintenance done  |