



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/07/2025

Area: IOSA

Equipment	Job
MANUAL YARD	LIGHTING DEFECTS RECTIFIED AND REPLACED DEFECTIVE LIGHT FITTING.
TBS	PCRD CHAIN TENSIONING UNIT BROKEN . TRIAL RUN TAKEN AFTER RECTIFICATION
OC-37A	PPM DONE ON MOTOR AND FIELD DEVICES. SPARE MOTOR MAINTENANCE DONE.