



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/06/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	scr 7 on cc39	slew not taking place/brake fail fault acted in spider of drive 2	reset done	16:45:00	17:00:00	
2	CHP	scr 5 on cc32	slew not taking place/out put fuse blown	glass fuse replaced	15:30:00	15:45:00	
3	WT	op 1	f/reverse not taking place	acb tripped/made on tested ok	15:40:00	15:50:00	