



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 31/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 25	luffing not taking place,d4 no contact loose connection	checked full luff ckt,loose wire tightened	15:30:00	15:58:00	
2	OHP	CO 26	olr acted	reset	15:50:00	15:59:00	
3	CHP	CC 51	MPD tripped 2 times	reset	19:30:00	19:35:00	
4	CHP	CC 131	olr acted	reset	20:35:00	20:40:00	
5	CHP	CC 12	brs problem,brs sensor misalignment	sensor adjusted	15:30:00	15:40:00	
6	CHP	CC 201	motor olr acted	reset	14:25:00	14:35:00	
7	CHP	CC 40 SCR2	slew not working,limit acted	released	16:20:00	16:35:00	
8	WT	OP5	no power,pusher @dead zone	pusher brought to power zone	16:00:00	16:20:00	