



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 31/12/2025

Area: IOSA

Equipment	Job
OC-27A	FIELD DEVICES FEEDBACK CHECKING DONE IN ZONE-3.
LIGHTING	OC-9A AND OC-11A LIGHTING CIRCUIT DEFECTS RECTIFIED AND SUFFICIENT LIGHTING PROVIDED.
OC-23A	FIELD DEVICES FEEDBACK CHECKING DONE. BRS IS IN BYPASS CONDITION.