



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/12/2025

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported tripped	OLR acted.Reset done(4 times)	22:40:00	04:40:00	
2	OHP	CO-33M	Reported tripped	OLR acted.Reset done	01:40:00	01:50:00	
3	CHP	CC-51	Reported tripped	MPD tripped.Feeding conveyor stopped.Reset done(4 times)	01:57:00	04:47:00	
4	CHP	CC-54	Reported tripped	OLR acted.Reset done	04:47:00	04:55:00	
5	CHP	CC-26 on CC-37	Position indication not coming	TT not placed properly	22:30:00	22:40:00	
6	CHP	CC 104 SCR-9	Luffing not taking place	MPCB tripped.Reset done(2 times)	00:45:00	05:00:00	
7	CHP	CC 105 SCR-10	LT not taking place	PCRD OT acted.Full drum cable found on ground.Rewinding done with guide adjustment(2 times)	01:55:00	03:30:00	
8	WT	OT-3	Reported tripped	D1 tripped on encoder fault.Reset done	03:15:00	03:20:00	