



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 67	olr acted	reset	03:50:00	03:55:00	
2	OHP	TT3 on co 8A	position bit missing,control fuse blown	fuse replaced	22:30:00	22:45:00	bypass removed in program
3	OHP	CO 11(C)	olr acted	reset	23:30:00	23:40:00	
4	OHP	BRC on CO 28	bc olr acted due to jamming	reset and informed operation	05:20:00	05:30:00	
5	OHP	BRC on Co 8A	b/w not running,oil level low	informed operation and mechanical	00:15:00	00:40:00	
6	OHP	TBS on co 19	right luff not taking place,mpd tripped	reset	05:58:00	06:18:00	
7	CHP	CC 28	olr acted	reset	00:00:00	00:10:00	
8	CHP	CC 33 scr 5	luffing down limit bypass request from operation	done, kept in ckt @0600	01:00:00	01:10:00	
9	CHP	CC 104 scr 9	slew not working,slew limit acted due to coal jamming	informed operation and limit reset	01:05:00	01:20:00	
10	CHP	CC 33 SCR5	Lt not working,pcrd motor olr acted	reset	02:40:00	02:50:00	
11	CHP	CC 31	mpr tripped	reset	03:00:00	03:10:00	
12	CHP	cc 37 SCR7	LT not working,M2 mpcb tripped,jamming	informed operation,and mpcb made on	03:41:00	03:55:00	
13	CHP	CC 33 SCR5	b/c not running,mpd tripped due to overload	reset	03:55:00	04:05:00	
14	CHP	CC 54	olr acted	reset	05:55:00	06:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	cc 51	mpd tripped 10 times	reset	23:45:00	03:35:00	
16	WT	OT2	d1 tripped in pgf1 fault	reset it done	02:10:00 03:35:00	02:10:00 03:40:00	OT 2 power and control made off and encoder removed for mech welding work
17	WT	op4	no fwd movement, initial not came due to mechanical problem	informed operation and mechanical	02:15:00	02:20:00	
18	WT	AF 2A	drive tripped in stall fault	reset it done	00:00:00	00:05:00	
19	WT	AF 2A	not moving, tripping immediately in stall fault after giving command, jamming in pan drive is taking 4 times more current	put AF in local, moved in REVERSE direction, jamming cleared	00:45:00	01:10:00	its mechanical and operation complaint
20	WT	OT 5	tippler not rotating, clamping problem	told operator to put in auto mode than do unclamp command than clamp	02:20:00	02:30:00	operator delay